



# Wedge Clamp




Swivel



Right-Angle



| TEST REPORT   |  |
|---|--|
| EN 74-1: 2005   |  |
| Couplers, spigot pins and baseplates for use in falsework and scaffolds   |  |
| Part 1: Couplers for tubes — Requirements and test procedures   |  |
| Report No.....  | GZ08110077-1   |
| Tested by (name and signature).....   | Clark Liu <i>Clark Liu</i>   |
| Approved by (name and signature).....   | John Qiao <i>John Qiao</i>   |
| Date of issue.....  | November 21, 2008  |
| Contents.....   | Total test report 6 pages including:<br>Report text: 3 pages<br>Appendix A for Test data: 2 pages<br>Appendix B for Product photos: 1 page |
| Testing Laboratory name.....  | Intertek Testing Services Shenzhen Ltd. Guangzhou Branch   |
| Address.....  | 1-8th floor, Block E2, 11 Cai Pin Road, Science city, Guangzhou Economic Development Zone, Guangzhou, P. R. China                          |
| Applicant's name.....   | SEM Metalworks (WUXI) Co., Ltd.  |
| Address.....  | 3# Xinzhai Road, Shuofang Industrial park, New District, Wuxi, Jiangsu, China  |
| Test specification:   |  |
| Standard.....   | EN 74-1: 2005  |
| Non-standard test method.....   | N/A  |
| Test Report Form No.....  | TTRF EN 74-1: 2005 A   |
| TTRF Originator.....  | Intertek Testing Services Shenzhen Ltd. Guangzhou Branch   |
| Master TTRF.....  | Dated 2008-11  |
| Test item description.....  | Right Angel Clamps   |
| Trade Mark.....   | "SS" with a Diamond Box                               |
| Model and/or type reference.....  | Tracking number: 03100830001   |
| Manufacturer.....   | —  |
| Rating(s).....  | Class B  |
| Summary of testing  |  |
| The Slipping force, Failure force, Pull-apart force, and Indentation of submitted samples were tested according to EN 74-1: 2005, and deemed to <b>COMPLY WITH</b> Class B requirements of EN 74-1: 2005. |  |
| TTRF EN 74-1: 2005 A<br>Originator: Intertek Testing Services Shenzhen Ltd. Guangzhou Branch  |  |



| Item                    | Finish        | Color  | Unit Weight |
|-------------------------|---------------|--------|-------------|
| Right Angle Wedge Clamp | Hot Dip Galv. | Silver | 3.22 lbs    |
| Swivel Wedge Clamp      | Hot Dip Galv. | Silver | 3.70 lbs    |